

Reference Number: FOIAH2425/202
From: Private Individual
Date: 15 July 2024
Subject: Monthly patient data and test results for Pseudomonas Aeruginosa Bacteraemia

Q1 Monthly patient data for Pseudomonas Aeruginosa Bacteraemia - for 2013, 2014, 2015, 2016 and 2017

Including:

- a) total number of patients tested
- b) total number of patients confirmed as infected
- c) total number of patients prescribed antibiotics
- d) broken down by name of antibiotic prescribed if possible

A1 a-b)

	Total Blood Culture Orders	Pseudomonas Positive Patients
2013	7,548	4
2014	7,328	6
2015	7,261	7
2016	6,958	5
2017	7,581	6

c-d) Information not held – the Trust does not routinely collate or hold this information centrally as part of its management or performance data. In order to confirm treatment following medication being dispensed, the Trust would be required to access personal data of the individuals and as such the data is exempt under Section 40: Personal data.

Q2 Monthly patient data for the tap/ sink water test results for Pseudomonas Aeruginosa Bacteraemia- for 2014, 2015, 2016 and 2017

Including:

- a) for the count per 100ml (or whatever volume was used for testing)
- b) for the neonatal unit
- c) for the neonatal ICU
- d) for the paediatric Unit
- e) or the maternity unit including post-natal wards

A2 a-d) Please see attached '202 FOI Response'. Please note that these results are from 2015-21 only. Preceding this, the Trust does not routinely collate or hold this information

centrally as part of its management or performance data.

e) Information not held- Alder Hey Children's NHS Foundation Trust is a specialist children's hospital and does not provide maternity services.

52	02.01.0135	Bed 6	HWB		0				0					1	0	0	0	0			>100	>1000	>100	>1000	>1000	0
53	02.01.0168	Bed 7	HWB		0				0					0			0	0			>100	0	>1000	0	>100	17
54	02.01.0167	Bed 8	HWB		0				0					0			0	0			6	0	0	0	0	0
55	02.01.0166	Bed 9	HWB	Tap number 002720	0				0					0			0	0			>100	>1000	>1000	0	>1000	>100
56	02.01.0165	Bed 10	HWB		0				0					0			0	0			>100	0	1	0	50-100	0
57	02.01.0164	Bed 11	HWB		0				0					0			0	>1000			0		0	5	>1000	
58	02.01.0163	Bed 12	HWB		0				0					0			0	0			0		0	42	50-100	
59	02.01.0143	Near patient testing	Decontamination		25	0	0	0	0					0			0	0			0		0	0	35	
132	02.01.0143	Near patient testing	HWB																						>1000	0
60	02.01.0141	Bed 13 lobby	HWB		0				0					0			0	0			0		0	0	0	0
61	02.01.0140	Bed 13	HWB		0				0					4	0	0	0	>100			>100	>1000	2	0	>1000	33
62		Dirty utility	HWB		0				0					0			0	0			0		0	0	0	0
63		Dirty utility	Decontamination		0				0					0			0	0			0		0	0	0	0
64	02.01.0061	Bed 30	HWB		0				0					0			0	0			>100	0	>1000	0	50-100	0
65	02.01.0060	Bed 31	HWB		0				0					0			0	0			>100	>100	>1000	0	1	0
66	02.01.0041	Bed 32	HWB		0				0					0			0	0			0		0	0	>1000	>1000
67	02.01.0040	Bed 33	HWB		0				0					0			0	>1000			100	5	>100	0	>1000	0
68	02.01.0039	Bed 34	HWB		>100	15	52	40	0					0			0	0			>100	>1000	>1000	0	0	0
69	02.01.0038	Bed 35	HWB		0				0					0			0	0			>100	0	0	0	0	1
70	02.01.0037	Bed 36	HWB		0				0					0			0	0			0		0	0	>1000	50-100
71	02.01.0036	Bed 37	HWB		>1000	0	0	0						0			0	>100			0		0	0	0	0
72	02.01.0067	Bed 38	HWB		0				0					0			0	>100			0		0	0	0	0
73	02.01.0066	Bed 39	HWB		>1000	>1000	0	0						0			>100	>1000			0		0	2	3	0
74	02.01.0104	WC accessible toilet	HWB		0				0					0			0	2	4	0						0
75	02.01.0132	Between Burns and theatre access	HWB		0				0					0			0	0			0		0	0	>1000	>1000
76	02.01.0108	Pharmacy resource	HWB		0				0					0			0	0			0		0	0	0	50
77	02.01.0108	Pharmacy resource	Decontamination		0				0					0			0	0			0		0	0	0	0
78	02.01.0109	Milk kitchen	HWB		0				0					0			0	0			0		0	0	0	0
79	02.01.0109	Milk kitchen	Decontamination		0				0					0			0	0			0		0	0	25	
80	02.01.0072	Dirty utility	HWB		>1000	0	>1000	>1000	0					>1000			>100	0			0		0	>100	>100	
81	02.01.0072	Dirty utility	Decontamination		0				0					0			0	0			0		0	0	0	0
82	02.01.0070	Bed 40	HWB		17	0	8	1	0					0			0	0			0		0	0	>100	25
83	02.01.0069	Bed 40 lobby	HWB		>1000	>1000	>1000	>1000	0					0			>100	0			0		0	1	0	0
84	02.01.0032	Bed 41	HWB		>1000	>100	>100	0						25			12	0			>100	>1000	0	>100	>1000	>100
85	02.01.0031	Bed 42	HWB		>100	27	>1000	27	0					0			0	0			0		0	0	>1000	>1000
86	02.01.0030	Bed 43	HWB		0				0					0			22	0			50-100	2	0	0	>100	22
87	02.01.0029	Bed 44	HWB		>100	>100	0	0						21			>1000	>1000			>100	>1000	0	0	>100	>100
88	02.01.0028	Bed 45	HWB		0				0					0			0	0			0	0	0	0	>100	>1000
89	02.01.0027	Bed 46	HWB		0				0					15			0	0			>100	0	0	7	>100	12
90	02.01.0076	Bed 47	HWB		0				0					0			0	10-100			>100	0	0	0	19	>100
91	02.01.0075	Bed 48	HWB		0				0					0			0	>1000			0		0	0	>100	0
92	02.01.0129	Dirty utility	HWB		>1000	>1000	>1000	>1000	0					0			>1000	0			0		0	0	>1000	18
93	02.01.0129	Dirty utility	Decontamination		0				0					0			0	0			0		0	0	0	0
131	02.1.0127	Sink next to dirty utility before beds 1-5	HWB																		0		0	0	>1000	>100
94	02.01.0177	Bed 1	HWB		0				0					0			0	0			0		0	0	0	0
95	02.01.0176	Bed 1 ensuite	Shower		0				32	37	1			>1000			>1000	>1000			>100		>1000	0	0	0
96	02.01.0176	Bed 1 ensuite	HWB		0				0					0			0	0			0		0	0	0	0
97	02.01.0175	Bed 2	HWB		0				0					0			0	0			0		0	0	>1000	>100
98	02.01.0174	Bed 2 ensuite	Shower		0				0					0			0	>100			0		0	0	0	0
99	02.01.0174	Bed 2 ensuite	HWB		0				0					0			0	0			0		0	0	0	0
100	02.01.0173	Bed 3	HWB		0				0					0			0	9	0	0	>100	0	0	0	0	0
101	02.01.0172	Bed 3 ensuite	Shower		0				0					100			0	0			0		0	0	0	0
102	02.01.0172	Bed 3 ensuite	HWB		0				0					0			0	>1000			0		0	4	>1000	
103	02.01.0171	Bed 4	HWB		0				0					0			0	0			0		0	0	0	0
104	02.01.0170	Bed 4 ensuite	Shower		0				>1000	100	10			100			0	0			0		0	0	0	0
105	02.01.0170	Bed 4 ensuite	HWB		0				0					0			0	0			0		0	0	0	0
106	02.01.0169	Bed 5	HWB		0				0					0			0	0			0		0	1	0	0

107	02.01.0168	Bed 5 ensuite	Shower							0					0			0	>100			0			0	37	0			
108	02.01.0168	Bed 5 ensuite	HWB							0					0			28	0			0			0	0	0			
109	02.01.0131	Domestic services	Decontamination							0					0			0	0											
110	02.01.0125	Play area opposite bed 1	Decontamination							0					0			0	0			0			0	0	0			
111	02.01.0123	IV prep	HWB							>100	0	0	0		0			0	0			0			0	>1000	37			
112	02.01.0122	Assessment room	HWB							0					0			0	0			0			0	0	0			
113	02.01.0179	Treatment bathroom	HWB - 1 (white)							>1000	>1000	0	0		0			0	0			0			0	>1000	54			
114	02.01.0179	Treatment bathroom	HWB - 2 (silver)							0					0			0	0			0			0	>100	32			
115	02.01.0179	Treatment bathroom	Bath main spout							0	0				0			0	0			0			0	0	0			
116	02.01.0179	Treatment bathroom	Bath left hose							0					0			100	0			0			31	7	7	>1000	100	0
117	02.01.0179	Treatment bathroom	Bath right hose							0					0				>100			10-100								
118	02.01.0121	Pantry	Decontamination - 1 (left)							0					0			0	0			0			0	0	0			
119	02.01.0121	Pantry	Decontamination - 2 (right)							0					0			0	0			0			0	0	0			
120		Treatment room	HWB	Tap number 002580						>100	>1000	>1000	44	0	0			0	0			0			0	>100	>1000			
121	02.01.0180	Therapy	HWB							0					0			0	0			0			0	1	0			
122	02.01.0180	Therapy	Decontamination							0					0			0	0			0			0	0	0			
123		WC staff	HWB							0					0			0	0			0			0	0	>100			
124		Sink next to lounge	HWB	Tap number 003049						0					0			0	0			0								
125	02.01.0082	WC accessible toilet	HWB							0					0			0	0			0								
126	02.01.0186	Staff change	HWB - 1	Tap number 002770						0					22	0	0	30			29				0	0				
127	02.01.0186	Staff change	HWB - 2	Tap number 002771						>100	0	0	0		0							>100	10-100							
128	02.01.0186	Staff change	Shower							0					0			0	0			0			0	0				
129	02.01.0185	WC	HWB							0					0			0	0			0			0	0				
130	02.01.0184	Staff rest	HWB							0					0			0	0			0			0	0				
131			HWB							0					0			0	0			0			0	0				

Ward	Outlet number	Room number	Room name	Water result of outlet	Swab type						
						21/05/2019	29/05/2019	04/06/2019	11/06/2019	19/06/2019	15/08/2019
W1C	Outlet 8	01.01.0106	Bed 19	No growth 25/03/19	Sink	No growth	No growth	No growth	No growth	No growth	No growth
					Under filter	No growth	No growth	No growth	No growth	No growth	No growth
					Side of filter	No growth	No growth	No growth	No growth	No growth	No growth
W1C	Outlet 27	01.01.0045	Bed 24	No growth 25/03/19	Sink	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>	No growth	<i>Pseudomonas aeruginosa</i>
					Under filter	No growth	No growth	No growth	No growth	No growth	No growth
					Side of filter	No growth	No growth	No growth	No growth	No growth	No growth
W1C	Outlet 24	01.01.0047	Bed 23	Pseudomonas isolated 25/03/19	Sink	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	No growth	No growth
					Under filter	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	No growth	No growth
					Side of filter	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	No growth	No growth
W1B	Outlet 61	02.01.0140	Bed 13	Pseudomonas isolated 14/05/19	Sink	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	No growth	No growth
					Under filter	No growth	No growth	No growth	No growth	No growth	No growth
					Side of filter	No growth	No growth	No growth	No growth	No growth	No growth
W1B	Outlet 28	02.01.0146	Bed 14	No growth 14/05/19	Sink	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	No growth	No growth
					Under filter	No growth	No growth	No growth	No growth	No growth	No growth
					Side of filter	No growth	No growth	No growth	No growth	No growth	No growth
W1B	Outlet 35	02.01.0151	Bed 21	Pseudomonas isolated 14/05/19	Sink	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>	<i>Pseudomonas aeruginosa</i>
					Under filter	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	<i>Pseudomonas aeruginosa</i>	No growth
					Side of filter	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	<i>Pseudomonas aeruginosa</i>	No growth
W1B	Outlet 67	02.01.0040	Bed 33	Pseudomonas isolated 14/05/19	Sink	<i>Pseudomonas aeruginosa</i>	No growth	No growth	No growth	No growth	No growth
					Under filter	No growth	No growth	No growth	No growth	No growth	<i>Pseudomonas aeruginosa</i>
					Side of filter	No growth	No growth	No growth	No growth	No growth	<i>Pseudomonas aeruginosa</i>
Ward 1C					Date on filter	03/04/2019	24/05/2019	24/05/2019	24/05/2019	24/05/2019	
Ward 1B					Date on filter	20/05/2019	20/05/2019	20/05/2019	20/05/2019	15/08/2019	